

Information requirements HDWI-MAXIMUS-95C / HDOI-MAXIMUS-95C

Function (indicate if present)				If function includes heating: Indicate the heating season the information relates to. Indicated values should relate to one heating season at a time. Include at least the heating season 'Average'.			
cooling	Y			Average (mandatory)	Y		
heating	Y			Warmer (if designated)	N		
				Colder (if designated)	N		
Item	symbol	value	unit	Item	symbol	value	unit
Design load				Seasonal efficiency			
cooling	Pdesignc	2.531	kW	cooling	SEER	6.69	—
heating/Average	Pdesignh	2.521	kW	heating/Average	SCOP/A	4.1	—
heating/Warmer	Pdesignh	2.762	kW	heating/Warmer	SCOP/W	5.16	—
heating/Colder	Pdesignh	—	kW	heating/Colder	SCOP/C	—	—
Declared capacity (*) for cooling, at indoor temperature 27(19) °C and outdoor temperature Tj				Declared energy efficiency ratio (*), at indoor temperature 27 (19) °C and outdoor temperature Tj			
Tj=35 °C	Pdc	2.531	kW	Tj=35 °C	EERd	3.33	—
Tj=30 °C	Pdc	1.93	kW	Tj=30 °C	EERd	5.1	—
Tj=25 °C	Pdc	1.214	kW	Tj=25 °C	EERd	8.19	—
Tj=20 °C	Pdc	0.849	kW	Tj=20 °C	EERd	12.99	—
Declared capacity (*) for heating/Average season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Average season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	2.23	kW	Tj = - 7 °C	COPd	3.05	—
Tj = 2 °C	Pdh	1.438	kW	Tj = 2 °C	COPd	4.08	—
Tj = 7 °C	Pdh	0.937	kW	Tj = 7 °C	COPd	4.82	—
Tj = 12 °C	Pdh	0.947	kW	Tj = 12 °C	COPd	6.07	—
Tj = operating limit	Pdh	2.162	kW	Tj = operating limit	COPd	2.6	—
Tj = bivalent temperature	Pdh	2.23	kW	Tj = bivalent temperature	COPd	3.05	—
Declared capacity (*) for heating/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*)/Warmer season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = 2 °C	Pdh	2.762	kW	Tj = 2 °C	COPd	3.1	—
Tj = 7 °C	Pdh	1.811	kW	Tj = 7 °C	COPd	4.83	—
Tj = 12 °C	Pdh	0.867	kW	Tj = 12 °C	COPd	5.95	—
Tj = operating limit	Pdh	2.762	kW	Tj = operating limit	COPd	3.1	—
Tj = bivalent temperature	Pdh	2.762	kW	Tj = bivalent temperature	COPd	3.1	—

Declared capacity (*) for heating/Colder season, at indoor temperature 20 °C and outdoor temperature Tj				Declared coefficient of performance (*) /Colder season, at indoor temperature 20 °C and outdoor temperature Tj			
Tj = - 7 °C	Pdh	N/A	kW	Tj = - 7 °C	COPd	N/A	—
Tj = 2 °C	Pdh	N/A	kW	Tj = 2 °C	COPd	N/A	—
Tj = 7 °C	Pdh	N/A	kW	Tj = 7 °C	COPd	N/A	—
Tj = 12 °C	Pdh	N/A	kW	Tj = 12 °C	COPd	N/A	—
Tj = bivalent temperature	Pdh	N/A	kW	Tj = bivalent temperature	COPd	N/A	—
Tj = operating limit	Pdh	N/A	kW	Tj = operating limit	COPd	N/A	—
Tj = - 15 °C	Pdh	N/A	kW	Tj = - 15 °C	COPd	N/A	—
Bivalent temperature				Operating limit temperature			
heating/Average	Tbiv	-7	°C	heating/Average	Tol	-10	°C
heating/Warmer	Tbiv	2	°C	heating/Warmer	Tol	2	°C
heating/Colder	Tbiv	N/A	°C	heating/Colder	Tol	N/A	°C
Cycling interval capacity				Cycling interval efficiency			
for cooling	Pcycc	N/A	kW	for cooling	EERcyc	N/A	—
for heating	Pcycc	N/A	kW	for heating	COPcyc	N/A	—
Degradation co-efficient cooling (**)	Cdc	0.25	—	Degradation co-efficient cooling (**)	Cdh	0.25	—
Electric power input in power modes other than 'active mode'				Annual electricity consumption			
off mode	POFF	0.00027	kW	cooling	QCE	132	kWh/a
standby mode	PSB	0.00027	kW	heating/Average	QHE	861	kWh/a
thermostat-off mode	PTO	0.03269	kW	heating/Warmer	QHE	749	kWh/a
Crankcase heater mode	PCK	0	kW	heating/Colder	QHE	—	kWh/a
Capacity control (indicate one of three options)				Other items			
fixed	N			Sound power level (indoor/outdoor)	L _{WA}	—	dB(A)
staged	N			Global warming	GWP	675	KgCO ₂ eq.
variable	Y			Rated air flow (indoor/outdoor)	—	—	m ³ /h
Contact details for obtaining more information	Guangdong Chigo Air-Conditioning Co., Ltd. Shengli Industry District, Lishui Town, Nanhai, Guangdong 528244, P.R.China http://www.china-chigo.com/cn/						
(*) For staged capacity units, two values divided by a slash ('/') will be declared in each box in the section 'Declared capacity of the unit' and 'declared EER/COP' of the unit. (**) If default Cd = 0,25 is chosen then (results from) cycling tests are not required. Otherwise either the heating or cooling cycling test value is required.							